

June 9, 2021

Mr. Marc Waters  
Ellicottville Central School District  
Superintendent of Buildings and Grounds  
5873 US-219  
Ellicottville, New York 14731

**RE: Investigation and Sampling of Drinking Water for Lead Concentrations**

Dear Mr. Waters:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Ellicottville Central School District, including:

- Ellicottville Central School – 5873 Route 219, Ellicottville, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on March 16, 2021. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 9 sources of potable water in the Ellicottville Central School building have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Ellicottville Central School District.

Sincerely,  
Stohl Environmental, LLC.



Eric Henderson Jr.  
Senior Project Manager

**Investigation and Sampling  
Of Sources of Potable Water  
For Lead Concentrations**

**Prepared for:**

**Ellicottville Central School District**

**Prepared by:**



**3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
[WWW.STOHLENVIRONMENTAL.COM](http://WWW.STOHLENVIRONMENTAL.COM)**

**Conditions as of March 16, 2021**

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

## 1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Ellicottville Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Ellicottville Central School – 5873 Route 219, Ellicottville, New York.

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Ellicottville Central School building. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

## 1.2 Executive Summary of Sampling and Analysis:

### Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Ellicottville Central School	3/16/2021	119	110	9	N/A	N/A

\*\* Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

### Listing of Outlets Requiring Remediation

#### Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
145.1-8	Kitchen Bathroom	Sink	49.8
145.1-41	Boys Locker Room Left Sink	Sink	216
145.1-42	Boys Locker Room Right Sink	Sink	17.9
145.1-81	Elementary Library	Sink	19.2
145.1-86	Room 172 Sink Facing Windows	Sink	16.0
145.1-87	Room 172 Sink Facing Left Wall	Sink	17.8
145.1-91	Room 171 Bubbler	Bubbler	25.2
145.1-122	Room 022 Bubbler	Bubbler	20.2
145.1-130	Girls Locker Room Left	Sink	25.0

### **1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

#### 1.4 Laboratory Analytical Reports by Building



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

Client: Stohl Environmental  
3860 California Road  
Orchard Park, NY 14127

Report Number: 21-03-04474

Received Date: 03/19/2021  
Reported Date: 06/08/2021  
Sampled By: Paul Nichols  
Tech Certification #:

Project/Test Address: 202L-145.1; Ellicottville Central School; 5873 Route 219; Ellicottville, NY 14731

Client Number:  
33-5980

# Laboratory Results

Fax Number:  
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-04474-001	145.1-1	03/16/2021	RECEIVING HANDWASH SINK	1.82	04/11/2021	
21-03-04474-002	145.1-4B	03/16/2021	BOTTLE FILL NEAR GYM	<1.00	04/11/2021	
21-03-04474-003	145.1-6	03/16/2021	KITCHEN ISLAND HANDWASH	4.46	04/11/2021	
21-03-04474-004	145.1-7	03/16/2021	KITCHEN POT FILL	3.22	04/11/2021	
21-03-04474-005	145.1-8	03/16/2021	KITCHEN BR	49.8	04/11/2021	
21-03-04474-006	145.1-9	03/16/2021	KITCHEN BACK HANDWASH	3.30	04/11/2021	
21-03-04474-007	145.1-10	03/16/2021	KITCHEN LEFT TRIPLE SINK	7.56	04/11/2021	
21-03-04474-008	145.1-11	03/16/2021	KITCHEN MIDDLE TRIPLE SINK	7.12	04/11/2021	
21-03-04474-009	145.1-12	03/16/2021	KITCHEN RIGHT TRIPLE SINK	12.4	04/11/2021	
21-03-04474-010	145.1-13	03/16/2021	DISHWASH SPRAYER	6.65	04/11/2021	
21-03-04474-011	145.1-14	03/16/2021	DISHWASH HANDWASH SINK	2.66	04/11/2021	
21-03-04474-012	145.1-15	03/16/2021	IM IN STORAGE	<1.00	04/11/2021	



# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-04474

Project/Test Address: 202L-145.1; Ellicottville Central School; 5873 Route  
219; Ellicottville, NY 14731

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-04474-013	145.1-16	03/16/2021	MAIN OFFICE BR	4.73	04/11/2021	
21-03-04474-014	145.1-17	03/16/2021	FACULTY WOMENS BR NEAR MAIN OFFICE	1.52	04/11/2021	
21-03-04474-015	145.1-18	03/16/2021	FACULTY MENS BR NEAR MAIN OFFICE	2.03	04/11/2021	
21-03-04474-016	145.1-19	03/16/2021	GIRLS BR NEAR MAIN OFFICE LEFT	1.58	04/12/2021	
21-03-04474-017	145.1-20	03/16/2021	GIRLS BR NEAR MAIN OFFICE LEFT MIDDLE	<1.00	04/11/2021	
21-03-04474-018	145.1-21	03/16/2021	GIRLS BR NEAR MAIN OFFICE RIGHT MIDDLE	2.48	04/11/2021	
21-03-04474-019	145.1-22	03/16/2021	GIRLS BR NEAR MAIN OFFICE RIGHT	2.14	04/11/2021	
21-03-04474-020	145.1-23	03/16/2021	BOYS BR NEAR MAIN OFFICE LEFT	<1.00	04/11/2021	
21-03-04474-021	145.1-25	03/16/2021	BOYS BR NEAR MAIN OFFICE RIGHT MIDLE	2.01	04/11/2021	
21-03-04474-022	145.1-26	03/16/2021	BOYS BR NEAR MAIN OFFICE RIGHT	<1.00	04/11/2021	
21-03-04474-023	145.1-28	03/16/2021	RIGHT DF NEAR ELEVATOR BY MAIN OFFICE	<1.00	04/11/2021	
21-03-04474-024	145.1-30	03/16/2021	LIBRARY MEDIA ROOM	12.5	04/11/2021	
21-03-04474-025	145.1-31	03/16/2021	BASEMENT FACULTY BR	2.58	04/11/2021	
21-03-04474-026	145.1-32	03/16/2021	ROOM 014	2.06	04/11/2021	
21-03-04474-027	145.1-33	03/16/2021	ROOM 007 BACK ROOM SINK	2.60	04/11/2021	
21-03-04474-028	145.1-34	03/16/2021	ROOM 008 DF	4.70	04/11/2021	
21-03-04474-029	145.1-35	03/16/2021	LEFT FACULTY BR NEAR GUIDANCE	14.5	04/11/2021	
21-03-04474-030	145.1-36	03/16/2021	RIGHT FACULTY BR NEAR GUIDANCE	7.52	04/11/2021	
21-03-04474-031	145.1-37	03/16/2021	BAND ROOM	1.36	04/11/2021	
21-03-04474-032	145.1-38	03/16/2021	ICE MACHINE NEAR FITNESS CENTER	<1.00	04/11/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-04474

Project/Test Address: 202L-145.1; Ellicottville Central School; 5873 Route  
219; Ellicottville, NY 14731

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-04474-033	145.1-39B	03/16/2021	BOTTLE FILL NEAR BOYS LR	<1.00	04/11/2021	
21-03-04474-034	145.1-40	03/16/2021	BOYS COACH'S OFFICE	6.76	04/11/2021	
21-03-04474-035	145.1-41	03/16/2021	BOYS LR LEFT SINK	216	04/12/2021	
21-03-04474-036	145.1-42	03/16/2021	BOYS LR RIGHT SINK	17.9	04/11/2021	
21-03-04474-037	145.1-43	03/16/2021	DF NEAR FITNESS CENTER LEFT	<1.00	04/11/2021	
21-03-04474-038	145.1-44B	03/16/2021	BOTTLE FILL NEAR FITNESS CENTER	<1.00	04/11/2021	
21-03-04474-039	145.1-45	03/16/2021	BOYS BR NEAR ART ROOM LEFT	1.84	04/11/2021	
21-03-04474-040	145.1-46	03/16/2021	BOYS BR NEAR ART ROOM MIDDLE	2.53	04/11/2021	
21-03-04474-041	145.1-47	03/16/2021	BOYS BR NEAR ART ROOM RIGHT	3.97	04/11/2021	
21-03-04474-042	145.1-48	03/16/2021	GIRLS BR NEAR ART ROOM LEFT	2.93	04/11/2021	
21-03-04474-043	145.1-49	03/16/2021	GIRLS BR NEAR ART ROOM MIDDLE	1.84	04/11/2021	
21-03-04474-044	145.1-50	03/16/2021	GIRLS BR NEAR ART ROOM RIGHT	1.39	04/11/2021	
21-03-04474-045	145.1-51	03/16/2021	ART ROOM MIDDLE HANDWASH	<1.00	04/11/2021	
21-03-04474-046	145.1-55	03/16/2021	GIRLS ELEMENTARY LR	2.36	04/11/2021	
21-03-04474-047	145.1-56	03/16/2021	BOYS ELEMENTARY LR LEFT	4.58	04/11/2021	
21-03-04474-048	145.1-57	03/16/2021	BOYS ELEMENTARY LR LEFT MIDDLE	9.08	04/11/2021	
21-03-04474-049	145.1-60	03/16/2021	GIRLS BR NEAR ELEMENTARY GYM	<1.00	04/11/2021	
21-03-04474-050	145.1-61	03/16/2021	BOYS BR NEAR ELEMENTARY GYM LEFT	2.60	04/11/2021	
21-03-04474-051	145.1-62	03/16/2021	BOYS BR NEAR ELEMENTARY GYM RIGHT	1.74	04/11/2021	
21-03-04474-052	145.1-63	03/16/2021	DF NEAR ELEMENTARY GYM	<1.00	04/11/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-04474

Project/Test Address: 202L-145.1; Ellicottville Central School; 5873 Route  
219; Ellicottville, NY 14731

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-04474-053	145.1-64	03/16/2021	ELEMENTARY KITCHEN DISHWASH SPRAYER	8.16	04/11/2021	
21-03-04474-054	145.1-65	03/16/2021	ELEMENTARY KITCHEN LEFT HANDWASH	8.16	04/11/2021	
21-03-04474-055	145.1-66	03/16/2021	ELEMENTARY KITCHEN RIGHT HANDWASH	6.95	04/11/2021	
21-03-04474-056	145.1-67	03/16/2021	NURSES OFFICE EXAM ROOM	10.4	04/11/2021	
21-03-04474-057	145.1-68	03/16/2021	NURSES OFFICE BR	4.84	04/11/2021	
21-03-04474-058	145.1-69	03/16/2021	PRINCIPALS OFFICE BR	2.40	04/11/2021	
21-03-04474-059	145.1-70	03/16/2021	ROOM 147 SINK	5.70	04/11/2021	
21-03-04474-060	145.1-72	03/16/2021	ROOM 146 SINK	5.64	04/11/2021	
21-03-04474-061	145.1-73	03/16/2021	HOME EC LEFT SINK	2.97	04/11/2021	
21-03-04474-062	145.1-74	03/16/2021	HOME EC LEFT SPRAYER	7.54	04/11/2021	
21-03-04474-063	145.1-75	03/16/2021	HOME EC RIGHT SINK	2.42	04/11/2021	
21-03-04474-064	145.1-76	03/16/2021	HOME EC RIGHT SPRAYER	8.03	04/11/2021	
21-03-04474-065	145.1-77	03/16/2021	ROOM 143 SINK	7.42	04/11/2021	
21-03-04474-066	145.1-78	03/16/2021	ROOM 135 SINK	2.73	04/11/2021	
21-03-04474-067	145.1-79	03/16/2021	ROOM 144 ACROSS FROM ROOM 134	1.27	04/11/2021	
21-03-04474-068	145.1-80	03/16/2021	ROOM 134 SINK	1.55	04/11/2021	
21-03-04474-069	145.1-81	03/16/2021	ELEMENTARY LIBRARY	19.2	04/11/2021	
21-03-04474-070	145.1-82	03/16/2021	ROOM 157 LEFT	1.03	04/11/2021	
21-03-04474-071	145.1-83	03/16/2021	ROOM 157 RIGHT	<1.00	04/11/2021	
21-03-04474-072	145.1-84	03/16/2021	ROOM 160 SINK	1.12	04/11/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-04474

Project/Test Address: 202L-145.1; Ellicottville Central School; 5873 Route  
219; Ellicottville, NY 14731

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-04474-073	145.1-85	03/16/2021	ROOM 160 BUBBLER	10.3	04/11/2021	
21-03-04474-074	145.1-86	03/16/2021	ROOM 172 SINK FACING WINDOWS	16.0	04/11/2021	
21-03-04474-075	145.1-87	03/16/2021	ROOM 172 SINK FACING LEFT WALL	17.8	04/11/2021	
21-03-04474-076	145.1-88	03/16/2021	ROOM 161 SINK	<1.00	04/11/2021	
21-03-04474-077	145.1-89	03/16/2021	ROOM 161 BUBBLER	4.86	04/11/2021	
21-03-04474-078	145.1-90	03/16/2021	ROOM 171 SINK	<1.00	04/11/2021	
21-03-04474-079	145.1-91	03/16/2021	ROOM 171 BUBBLER	25.2	04/11/2021	
21-03-04474-080	145.1-92	03/16/2021	ROOM 162 SINK	<1.00	04/11/2021	
21-03-04474-081	145.1-93	03/16/2021	ROOM 162 BUBBLER	8.98	04/11/2021	
21-03-04474-082	145.1-94	03/16/2021	ROOM 170 SINK	<1.00	04/11/2021	
21-03-04474-083	145.1-95	03/16/2021	ROOM 170 BUBBLER	5.16	04/11/2021	
21-03-04474-084	145.1-96	03/16/2021	ROOM 163 SINK	<1.00	04/11/2021	
21-03-04474-085	145.1-97	03/16/2021	ROOM 163 BUBBLER	9.45	04/11/2021	
21-03-04474-086	145.1-98	03/16/2021	ROOM 169 SINK	<1.00	04/11/2021	
21-03-04474-087	145.1-99	03/16/2021	ROOM 169 BUBBLER	2.73	04/11/2021	
21-03-04474-088	145.1-100	03/16/2021	DF NEAR ROOM 1649	6.50	04/11/2021	
21-03-04474-089	145.1-101	03/16/2021	ROOM 164 SINK	<1.00	04/11/2021	
21-03-04474-090	145.1-102	03/16/2021	ROOM 164 BUBBLER	5.90	04/11/2021	
21-03-04474-091	145.1-103	03/16/2021	ROOM 168 SINK	<1.00	04/11/2021	
21-03-04474-092	145.1-104	03/16/2021	ROOM 168 BUBBLER	4.06	04/11/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-04474

Project/Test Address: 202L-145.1; Ellicottville Central School; 5873 Route  
219; Ellicottville, NY 14731

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-04474-093	145.1-105	03/16/2021	ROOM 165 SINK	3.73	04/11/2021	
21-03-04474-094	145.1-106	03/16/2021	ROOM 168 BUBBLER	<1.00	04/11/2021	
21-03-04474-095	145.1-107	03/16/2021	ROOM 167 SINK	<1.00	04/11/2021	
21-03-04474-096	145.1-108	03/16/2021	ROOM 167 BUBBLER	1.50	04/11/2021	
21-03-04474-097	145.1-109	03/16/2021	ROOM 166 SINK	<1.00	04/11/2021	
21-03-04474-098	145.1-110	03/16/2021	ROOM 166 BUBBLER	7.32	04/11/2021	
21-03-04474-099	145.1-111	03/16/2021	ROOM 025 SINK	1.37	04/11/2021	
21-03-04474-100	145.1-112	03/16/2021	ROOM 025 BUBBLER	3.35	04/11/2021	
21-03-04474-101	145.1-113	03/16/2021	ROOM 024 SINK	1.16	04/11/2021	
21-03-04474-102	145.1-114	03/16/2021	ROOM 024 BUBBLER	<1.00	04/11/2021	
21-03-04474-103	145.1-115	03/16/2021	ROOM 026 SINK	1.40	04/11/2021	
21-03-04474-104	145.1-116	03/16/2021	ROOM 026 BUBBLER	1.77	04/11/2021	
21-03-04474-105	145.1-117	03/16/2021	ROOM 025 SINK	1.26	04/11/2021	
21-03-04474-106	145.1-119	03/16/2021	ROOM 027 SINK	2.89	04/11/2021	
21-03-04474-107	145.1-120	03/16/2021	ROOM 022 LEFT SINK	2.88	04/11/2021	
21-03-04474-108	145.1-121	03/16/2021	ROOM 022 RIGHT SINK	<1.00	04/11/2021	
21-03-04474-109	145.1-122	03/16/2021	ROOM 022 BUBBLER	20.2	04/11/2021	
21-03-04474-110	145.1-123	03/16/2021	GIRLS BR	7.16	04/11/2021	
21-03-04474-111	145.1-124	03/16/2021	DF NEAR ROOM 020	2.48	04/11/2021	
21-03-04474-112	145.1-125	03/16/2021	BOYS BR	1.70	04/11/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980  
Project/Test Address: 202L-145.1; Ellicottville Central School; 5873 Route  
219; Ellicottville, NY 14731

Report Number: 21-03-04474

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-04474-113	145.1-126	03/16/2021	CONCESSION IN CAFE SINK	2.52	04/12/2021	
21-03-04474-114	145.1-127	03/16/2021	CONCESSION IN CAFE SPRAYER	1.82	04/12/2021	
21-03-04474-115	145.1-128B	03/16/2021	BOTTLE FILL NEAR GIRLS LR	<1.00	04/12/2021	
21-03-04474-116	145.1-129	03/16/2021	GIRLS COACH'S OFFICE	7.65	04/12/2021	
21-03-04474-117	145.1-130	03/16/2021	GIRLS LR LEFT	25.0	04/12/2021	
21-03-04474-118	145.1-131	03/16/2021	GIRLS LR RIGHT	2.63	04/12/2021	
21-03-04474-119	145.1-132	03/16/2021	BUS GARAGE BR	7.69	04/12/2021	

Method: EPA 200.8  
Analyst: Anthony Dee  
Accreditation #: NY 11714

Reviewed By Authorized Signatory:

*Melissa Kanode*

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

## 1.5 Laboratory Certifications



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2022  
Issued April 01, 2021  
Revised April 02, 2021

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MS. JULIE DICKERSON  
ENVIRONMENTAL HAZARDS SERVICES, LLC  
7469 WHITEPINE ROAD  
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Arsenic, Total	EPA 200.8 Rev. 5.4
Copper, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Lead, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.8 Rev. 5.4

NEW YORK  
STATE OF  
OPPORTUNITY.

Department  
of Health

Serial No.: 63485

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.





## 1.6 Chains of Custody



3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-145.1

Client: Ellicottville CSD

Contact: Marc Waters

Building: Ellicottville Central School


Location: 5873 Route 219 Ellicottville, NY 14731

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	21-03-04474	Outlet Type	Time
145.1-1	Receiving Handwash Sink		S	4:20
145.1-4B	Bottle Fill Near Gym		DFB	4:21
145.1-6	Kitchen Island Handwash		S	4:22
145.1-7	Kitchen Pot Fill		S	4:23
145.1-8	Kitchen BR		S	4:24
145.1-9	Kitchen Back Handwash		S	4:25
145.1-10	Kitchen Left Triple Sink		S	4:26
145.1-11	Kitchen Middle Triple Sink		S	4:27
145.1-12	Kitchen Right Triple Sink		S	4:28
145.1-13	Dishwash Sprayer		S	4:29
145.1-14	Dishwash Handwash Sink		S	4:30
145.1-15	IM in Storage		IM	4:31
145.1-16	Main Office BR	S	4:32	
145.1-17	Faculty Womens BR Near Main Office	S	4:33	
145.1-18	Faculty Mens BR Near Main Office	S	4:34	
145.1-19	Girls BR Near Main Office Left	S	4:35	
145.1-20	Girls BR Near Main Office Left Middle	S	4:36	
145.1-21	Girls BR Near Main Office Right Middle	S	4:37	

### Notes:

Please e-mail lab results to [labs@stohlenvironmental.com](mailto:labs@stohlenvironmental.com)

☒ If checked, also e-mail results to:

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 3/15/2021 3/16/21 (ms)

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/17/2021

Received (Name / Lab): T. Johnson Date: 3/19/21 Time: 12

Sample Login (Name / Lab): Traci Brown / Paul Nichols Date: 4/1/21 Time: 7:50 AM

Analysis (Name / Lab): Erin O'Connell Date: 4/1/21 Time: 4:33 PM

QA/QC Review (Name / Lab): Michelle Date: 4/1/21 Time: 5 PM

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-145.1

Client: Ellicottville CSD

Contact: Marc Waters

Building: Ellicottville Central School

Location: 5873 Route 219 Ellicottville, NY 14731

## LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
145.1-22	Girls BR Near Main Office Right	S	4:38
145.1-23	Boys BR Near Main Office Left	S	4:39
145.1-25	Boys BR Near Main Office Right Middle	S	4:40
145.1-26	Boys BR Near Main Office Right	S	4:41
145.1-28	Right DF Near Elevator by Main Office	DF	4:42
145.1-30	Library Media Room	S	4:43
145.1-31	Basement Faculty BR	S	4:44
145.1-32	Room 014	S	4:45
145.1-33	Room 007 Back Room Sink	S	4:46
145.1-34	Room 008 DF	DF	4:47
145.1-35	Left Faculty BR Near guidance	S	4:48
145.1-36	Right Faculty BR Near Guidance	S	4:49
145.1-37	Band Room	S	4:50
145.1-38	Ice Machine Near Fitness Center	IM	4:51
145.1-39B	Bottle Fill Near Boys LR	DFB	4:52
145.1-40	Boys Coach's Office	S	4:53
145.1-41	Boys LR Left Sink	S	4:54
145.1-42	Boys LR Right Sink	S	4:55

## Notes:

Please e-mail lab results to labs@stohlenv.com

Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 3/16/2021 2/16/21 (MS)

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/17/2021

Received (Name / Lab): T. Adams Date: 3/19/21 Time: 12

Sample Login (Name / Lab): Traci Bloom / Paul Bloom Date: 4/7/21 Time: 7:55 AM

Analysis (Name / Lab): Tracy O'Neil Date: 4/12/21 Time: 4:33 PM

QA/QC Review (Name / Lab): M. Smith Date: 4/15/21 Time: 5 PM

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-145.1

Client: Ellicottville CSD

Contact: Marc Waters

Building: Ellicottville Central School

Location: 5873 Route 219 Ellicottville, NY 14731

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
145.1-43	DF Near Fitness Center Left	DF	4:56
145.1-44B	Bottle Fill Near Fitness Center	DFB	4:57
145.1-45	Boys BR Near Art Room Left	S	4:58
145.1-46	Boys BR Near Art Room Middle	S	4:59
145.1-47	Boys BR Near Art Room Right	S	5:00
145.1-48	Girls BR Near Art Room Left	S	5:01
145.1-49	Girls BR Near Art Room Middle	S	5:02
145.1-50	Girls BR Near Art Room Right	S	5:03
145.1-51	Art Room Middle Handwash	S	5:04
145.1-55	Girls Elementary LR	S	5:05
145.1-56	Boys Elementary LR Left	S	5:06
145.1-57	Boys Elementary LR Left Middle	S	5:07
145.1-60	Girls BR Near Elementary Gym	S	5:08
145.1-61	Boys BR Near Elementary Gym Left	S	5:09
145.1-62	Boys BR Near Elementary Gym Right	S	5:10
145.1-63	DF Near Elementary Gym	DF	5:11
145.1-64	Elementary Kitchen Dishwash Sprayer	S	5:12
145.1-65	Elementary Kitchen Left Handwash	S	5:13

### Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 3/15/2021 3/16/21 (MS)  
 Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/17/2021  
 Received (Name / Lab): T. Henson Date: 3/19/21 Time: 12  
 Sample Login (Name / Lab): T. Henson / Paul Nichols Date: 4/7/21 Time: 7:57 AM  
 Analysis (Name / Lab): Joey Dece Date: 4/14/21 Time: 11:33 pm  
 QA/QC Review (Name / Lab): M. Henson Date: 4/15/21 Time: 5 pm  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-145.1

Client: Ellicottville CSD Contact: Marc Waters

Building: Ellicottville Central School Location: 5873 Route 219 Ellicottville, NY 14731

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
145.1-66	Elementary Kitchen Right Handwash	S	5:14
145.1-67	Nurses Office Exam Room	S	5:15
145.1-68	Nurses Office BR	S	5:16
145.1-69	Principals Office BR	S	5:17
145.1-70	Room 147 Sink	S	5:18
145.1-72	Room 146 Sink	S	5:19
145.1-73	Home Ec Left Sink	S	5:20
145.1-74	Home Ec Left Sprayer	S	5:21
145.1-75	Home Ec Right Sink	S	5:22
145.1-76	Home Ec Right Sprayer	S	5:23
145.1-77	Room 143 Sink	S	5:24
145.1-78	Room 135 Sink	S	5:25
145.1-79	Room 144 Across From Room 134	S	5:26
145.1-80	Room 134 Sink	S	5:27
145.1-81	Elementary Library	S	5:28
145.1-82	Room 157 Left	S	5:29
145.1-83	Room 157 Right	S	5:30
145.1-84	Room 160 Sink	S	5:31

### Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 3/16/21 (M)  
Relinquished By: E. Henderson Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/17/2021  
Received (Name / Lab): T. Johnson Date: 3/19/21 Time: 130  
Sample Login (Name / Lab): Tina Blum / Paul Blum Date: 4/7/21 Time: 800AM  
Analysis (Name / Lab): Young Oak Date: 4/14/21 Time: 4:33pm  
QA/QC Review (Name / Lab): M. Smith Date: 4/15/21 Time: 5pm  
Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



3850 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHL-ENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-145.1

Client: Ellicottville CSD Contact: Marc Waters

Building: Ellicottville Central School Location: 5873 Route 219 Ellicottville, NY 14731

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
145.1-85	Room 160 Bubbler	B	5:32
145.1-86	Room 172 Sink Facing Windows	S	5:33
145.1-87	Room 172 Sink Facing Left Wall	S	5:34
145.1-88	Room 161 Sink	S	5:35
145.1-89	Room 161 Bubbler	B	5:36
145.1-90	Room 171 Sink	S	5:37
145.1-91	Room 171 Bubbler	B	5:38
145.1-92	Room 162 Sink	S	5:39
145.1-93	Room 162 Bubbler	B	5:40
145.1-94	Room 170 Sink	S	5:41
145.1-95	Room 170 Bubbler	B	5:42
145.1-96	Room 163 Sink	S	5:43
145.1-97	Room 163 Bubbler	B	5:44
145.1-98	Room 169 Sink	S	5:45
145.1-99	Room 169 Bubbler	B	5:46
145.1-100	DF Near Room 1649	DF	5:47
145.1-101	Room 164 Sink	S	5:48
145.1-102	Room 164 Bubbler	B	5:49

### Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 3/15/2021 3/16/21 (nw)

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/17/2021

Received (Name / Lab): T. H. Date: 3/16/21 Time: 12p

Sample Login (Name / Lab): Traci Brown / Stohl Env Date: 4/7/21 Time: 8:05AM

Analysis (Name / Lab): John Doe Date: 4/12/21 Time: 4:33p

QA/QC Review (Name / Lab): M. H. Date: 4/15/21 Time: Spn

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

9474



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
[WWW.STOHLENVIRONMENTAL.COM](http://WWW.STOHLENVIRONMENTAL.COM)

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-145.1

Client: Ellicottville CSD Contact: Marc Waters

Building: Ellicottville Central School Location: 5873 Route 219 Ellicottville, NY 14731

## LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
145.1-103	Room 168 Sink	S	5:50
145.1-104	Room 168 Bubblers	B	5:51
145.1-105	Room 165 Sink	S	5:52
145.1-106	Room 168 Bubblers	B	5:53
145.1-107	Room 167 Sink	S	5:54
145.1-108	Room 167 Bubblers	B	5:55
145.1-109	Room 166 Sink	S	5:56
145.1-110	Room 166 Bubblers	B	5:57
145.1-111	Room 025 Sink	S	5:58
145.1-112	Room 025 Bubblers	B	5:59
145.1-113	Room 024 Sink	S	6:00
145.1-114	Room 024 Bubblers	B	6:01
145.1-115	Room 026 Sink	S	6:02
145.1-116	Room 026 Bubblers	B	6:03
145.1-117	Room 025 Sink	S	6:04
145.1-119	Room 027 Sink	S	6:05
145.1-120	Room 022 Left Sink	S	6:06
145.1-121	Room 022 Right Sink	S	6:07

## Notes:

Please e-mail lab results to [labs@stohlenvironmental.com](mailto:labs@stohlenvironmental.com)

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 3/15/2021 3/16/21 65

Relinquished By: E. Henderson Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/17/2021

Received (Name / Lab): T. Bloom / Paul Bloom Date: 3/17/21 Time: 12

Sample Login (Name / Lab): T. Bloom / Paul Bloom Date: 4/7/21 Time: 20847

Analysis (Name / Lab): Joey O'Connell Date: 4/12/21 Time: 4:30pm

QA/QC Review (Name / Lab): Meun Date: 4/15/21 Time: 5pm

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



## Chain of Custody Document

Submitted to: (Lab Name) EHS

**3860 California Road, Orchard Park, New York 14127**  
**PHONE (716) 312-0070 FAX (716) 312-8092**  
**WWW.STOHLENVIRONMENTAL.COM**

STOHL Job # 2020L-145.1

Client: Ellicottville CSD Contact: Marc Waters

Building: Ellicottville Central School Location: 5873 Route 219 Ellicottville, NY 14731

**LEAD**

Water by SM 19, 21 - 23 3113B (-04, -10)	X
--	---

## Turnaround

20 Days

[illegible]

Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

Ehenderson@StohlEnv.com

Sampled By: Paul Nichols      Print Name      Stohl Env: Paul Nichols      Date: 3/15/2021      3/15/21

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/17/2021

Received (Name / Lab): Taha / Date: 7/9/21 Time: 12

Sample Login (Name / Lab): Travis Adams / Lab 10 Date: 4/7/21 Time: 2:15 PM

Analysis (Name / Lab): Yamir Lopez Date: 4/17/11 Time: 11:30

QA/QC Review (Name / Lab): M. J. / Date: 11/11/11 Time: 5:00

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: 11/5/11 Time: 3:11



BLANK

BLANK

BLANK



**3860 California Road, Orchard Park, New York 14127**

**PHONE (716) 312-0070 FAX (716) 312-8092**

**[WWW.STOHLENVIRONMENTAL.COM](http://WWW.STOHLENVIRONMENTAL.COM)**